

JAWAHARLAL NEHRU PORT AUTHORITY-SEZ

Annexure-VII- Performance Report regarding Reliability Indices.

Formats for Quarterly returns Sep 2026 to be submitted to the Commission by the Distribution Licensee

1) System Average Interruption Duration Index (SAIDI)

Sr No	Month	Ni=Number of Consumers Who experienced a sustained interruption on ith feeder.	Ri=Restoration time for each interruption event on ith feeder	Nt=Total number of consumers of the distribution Licensees area.	Sum.(Ri*Ni) for all feeders excluding agriculture feeders	SAIDI=(6)/(5)
[1]	[2]	[3]	[4]	[5]	[6]	[7]
1	Sep-26	36	7	36	252	7
	Total			36	252	7

2) System Average Interruption Frequency Index (SAIFI)

Sr No	Month	Ni=Number of Consumers Who experienced a sustained interruption on ith feeder.	Sum of Consumers of i feeders which had experienced interruptions =Sum Ni	Nt=Total number of consumers of the distribution Licensees area.	SAIFI=(4)/(5)
[1]	[2]	[3]	[4]	[5]	[6]
1	Sep-26	36	36	36	1
	Total		36	36	1

3) Customer Average Interruption Duration Index (CAIDI)

Sr No	Month	SAIDI	SAIFI	SAIDI/SAIFI
[1]	[2]	[3]	[4]	[5]
1	Sep-26	7	1	7
	Total	7	1	7

4) Customer Average Interruption Duration Index (CAIDI) for HT consumers

Sr No	Month	Ni=Number of HT consumers who experienced a sustained interruption	Ri=Restoration time for each interruption event on HT feeder	sum.(Ri*Ni) for all HT consumers	CAIDI=(5)/(3)
[1]	[2]	[3]	[4]	[5]	[6]
1	Sep-26	11	7	77	7
	Total	11		77	7

Authorised Signatory

(Milind Aigalika | Sr. Manager (M. & E.E.)

M +91 9819772765

milindaigalika@jnport.gov.in

Milind Aigalika



जनपद प्राधिकरण
JNPA

वरिष्ठ प्रबंधक (या. एवं वि. अभि.)
Senior Manager (M & E.E.)
ज.ने.प. प्राधिकरण, शेवा, नवी मुंबई 400707
J.N.P.A., Sheva, Navi Mumbai 400707